



Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)526-0135

Public Water System Bacteriological Report

PWS Name : CASS COUNTY PWSD 8
Mail to : ALAN QUIGLEY
411 E 165TH ST
BELTON, MO 64012

PWS ID : MO1024119

County : CASS

Please notify us of any
name and address changes

Date Collected : 02/07/2024	Collector : MENO,IGNACIO	Sample Type : Routine	
Lab Sample ID : OE981497	Location Name: 16 E 165TH ST	Location ID: 15	Lab Results : A

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples.

Tuesday, February 13, 2024